

**ADDENDUM #2**  
**September 19, 2017**  
**CONTRACT DOCUMENTS**  
**Fishersville WWTF HVAC Improvements**

**General:**

1. This Addendum provides answers to submitted questions. There are no changes to the Plans or Contract Documents.

**Questions & Answers:**

1. Do the existing air flow measurement stations have a 0-10 Vdc output signal?  
*Per the original control drawings, the existing AFMs have 2-10VDC output signals.*